



ADDENDUM # 4
BID # FY 2019-2020-001 CITY OF HALLANDALE BEACH
LIFT STATION # 8 REPLACEMENT

Please ensure you check the City's website for the latest addendum released for this project. Below find the link to the City's website: www.cohb.org/solicitations.

Proposing firms must provide this Addendum # 4 form signed by an authorized officer of the firm to acknowledge receipt of ADDENDUM # 4. The form must be provided with firm's response.

PLEASE NOTE:

QUESTION #1.

Has the existing VCP gravity sewer been lined or will the City have the sewer lined prior to commencement of this project in order to mitigate disruption and damage to the existing sewer?

ANSWER #1.

No, the existing VCP gravity main has not been lined, however the city is planning on lining the pipe prior to the construction of this project.

PLEASE NOTE RECEIPT OF ADDENDUM # 4 BY SIGNING BELOW AND INCLUDE WITH YOUR FIRM'S SUBMISSION.

I ACKNOWLEDGE RECEIPT OF ADDENDUM # 4:

Company	
Name	
Title	
Signature	
Date	

Sincerely,

Andrea Lues

Andrea Lues, Director, Procurement Department